



भारत सरकार Government of India  
राष्ट्रीय परीक्षण शाला (उ.क्षे.)  
National Test House (NR)  
राष्ट्रीय परीक्षण शाला (उ.क्षे.), कमला नेहरू नगर, गाजियाबाद, उत्तर प्रदेश - 201002  
Kamla Nehru Nagar, Ghaziabad, Uttar Pradesh - 201002



PART A. PARTICULARS OF SAMPLE SUBMITTED

COMPLETE TEST REPORT

भाग 'अ' जमा किये गये नमूने का विवरण

परीक्षण प्रमाणपत्र सं/Test Certificate No: NTH(NR)/CH(G)/22/1593\_1 SRF Number: NTH(NR)/CH(G)/22/1593 जारी होने की तिथि/Date of issue 20 Dec, 2022 कोड सं/QR Code/Barcode : NTH220013065

- a) जिसे जारी करना है/Issued To : Scholars International School
- b) पता/Address : 363-364, Pandav Nagar Industrial Area, Ghaziabad, Ghaziabad, Uttar Pradesh, India - 201002
- c) ग्राहक का संदर्भ सं एवं दिनांक/Customer's Ref. No. : SISG/WT/19 dated 6/12/2022
- d) नमूना मुहरबंद स्थिति/Sample Sealed Status : Sealed
- e) परीक्षण सामग्री का विवरण/Description of Test Item : Water Sample Collected from boring ( submersible pump) opposite the school building
- f) नमूना का विशिष्टता (यदि हो)/Product Specification(if any) : IS 10500 (2012) - Drinking Water - Specification (Second Revision)
- g) नमूना प्राप्ति की तिथि /Date of Receipt of the Test item : 06 Dec, 2022
- h) कार्य सम्पादन की तिथि/Date(s)of Performance of Tests : From: 19 Dec, 2022 To: 19 Dec, 2022
- i) Quantity : 1.0 5 ltr & 1 ltr
- j) Any other Information / Expiry Date, If any : ALL TESTS as per IS:10500-2012
- k) Section Code : 22CH64B7N
- l) Section Report No. : 22CH64B7N\_1
- m) Report Type : New
- n) Reference Report No. :
- o) Remarks : Test Report forwarded.

VISHWANATH GUPTA  
OIC SAMPLE CELL  
(Authorized Signatory)  
Authorized on: 20 Dec, 2022 17 22 PM

This is a Computer Generated Report.

Scholars International School

*Becha*  
Principal

*Shefali Kantam*  
MANAGER  
SCHOLARS INTERNATIONAL SCHOOL  
GZB



Section Report No. : 22CH64B7N\_1

IS 10500 (2012)

PART B. SUPPLEMENTARY INFORMATION

1. नमूना लेने की प्रक्रिया का संदर्भ, जहां लागू हो। Reference to sampling procedure, wherever applicable.	Not Applicable
2. परीक्षण रिपोर्ट से संबंधित मापन एवं परिमाण प्रति हेतु सहायक प्रलेख जैसे ग्राफ, तालिका, चित्र और / अथवा फोटोग्राफ, यदि कोई हो। Supporting documents for the measurements taken and results derived like graphs, table sketches and or photographs as appropriate to test report, if any.	Not Applicable
3. सम्बद्ध मानक / कार्य निर्देशों में निर्धारित परीक्षण पद्धति से विचलन, यदि कोई हो। Deviation from the test methods as prescribed in relevant ISS/Work instruction, if any.	Not Applicable
4. परीक्षण सामग्री की पहचान/identification of Test item	Water Sample Collected from boring (submersible pump) opposite the school building
5. व्यावृत्त की प्राणाली की पहचान/Method(s) used for Test	IS:3025
6. नमूना प्रक्रिया जहां प्रासंगिक हो/Sampling Procedure where relevant	..
7. पर्यावरण की स्थिति/Environmental Conditions	MAINTAINED
8. उपयोग किए जाने वाले प्रमुख मानक/उपकरण/Major Standards/Equipments used	ICP-OES
9. कैलिब्रेशन स्थल/Site of Calibration	..
10. मापन का पता लगाने की क्षमता/Traceability of Measurement	..

ANSHU MALA SHUKLA  
OIC Testing/Calibration Chemical (General, Standard, Metal, Oil Fuel)  
(Authorized Signatory)  
Authorized on: 19 Dec. 2022 16:26 PM

This is a Computer Generated Report.

Scholars International School  
Becha  
Principal

*Shefali Kantam*  
MANAGER  
SCHOLARS INTERNATIONAL SCHOOL  
GZB. ★ 100HS



Section Report No. : 22CH64B7N\_1

IS 10500 (2012)

PART C. TEST RESULT

S.No.	Clause No Table No. Sl. No	Parameter - Method of test	Test Description	Min Limit	Max Limit	Unit	Result/ Observation
1	4	Free residual chlorine	mg/l				0
2	4	Colour	Hazen Units				less than 5 Hz unit.
3	4	Total Dissolved Solids	mg/l		500.0	mg/l	240.0
4	4	Aluminium (as Al)	mg/l		0.03	mg/l	0.03
5	4	Copper (as Cu)	mg/l		0.5	mg/l	0.003
6	4	Calcium (as Ca)	mg/l		75.0	mg/l	27.09
7	4	Iron (as Fe)	mg/l		1.0	mg/l	0
8	4	Magnesium (as Mg)	mg/l		30.0	mg/l	10.5
9	4	Manganese (as Mn)	mg/l		0.1	mg/l	0
10	4	Nitrate (as NO3)	mg/l		45.0	mg/l	5.25
11	4	Selenium (as Se)	mg/l		0.01	mg/l	0.004
12	4	Turbidity	NTU		1.0	NTU	0.42
13	4	Chloride (as Cl)	mg/l		250.0	mg/l	16.18
14	4.1	Total Coliform Bacteria per 100 ml	Total Coliform Bacteria per 100 ml				Absent/100ml
15	4.1	Escherichia coli per 100 ml	Escherichia coli per 100 ml				Absent/100ml
16	4	pH value	pH	6.5	8.5		7.5
17	4	Silver (as Ag)	mg/l		0.1	mg/l	0
18	4	Sulphate (as SO4)	mg/l		200.0	mg/l	29.38
19	4	Total alkalinity as Calcium carbonate	mg/l		200.0	mg/l	166.25
20	4	Total Hardness (as CaCO3)	mg/l		200.0	mg/l	110.98
21	4	Zinc (as Zn)	mg/l		5.0	mg/l	0.029
22	4	Cadmium (as Cd)	mg/l		0.003	mg/l	0
23	4	Lead (as Pb)	mg/l		0.01	mg/l	0
24	4	Mercury (as Hg)	mg/l		0.001	mg/l	0
25	4	Molybdenum (as Mo)	mg/l		0.07	mg/l	0
26	4	Nickel (as Ni)	mg/l		0.02	mg/l	0
27	4	Total Arsenic (as As)	mg/l		0.01	mg/l	0
28	4	Total Chromium (as Cr)	Total Chromium (as Cr)		0.05	mg/l	0
29	4	Odour	Agreeable				Agreeable

Sudhakar Jaiswal  
Lab Sc. Testing/Calibration Chemical (General, Standard,  
Metal, Oil Fuel)  
(Authorized Signatory)

ANSHU MALA SHUKLA  
OIC Testing/Calibration Chemical (General, Standard,  
Metal, Oil Fuel)  
(Authorized Signatory)  
Authorized on: 19 Dec. 2022 16 26 PM

This is a Computer Generated Report.



Section Report No. : 22CH64B7N\_1

IS 10500 (2012)

**PART D. REMARKS**

The sample meets the chemical requirements of IS 10500-2012 (RA 2018) for Water Sample Collected from boring ( submersible pump) opposite the school building in respect of the tests carried out.

**PART D. Notes**

--

**ANSHU MALA SHUKLA**  
OIC Testing/Calibration Chemical (General, Standard, Metal, Oil Fuel)  
(Authorized Signatory)  
Authorized on: 19 Dec. 2022 16:26 PM

This is a Computer Generated Report.

Scholars International School  
Bocha  
Principal

*Sheela Kantam*  
MANAGER  
SCHOLARS INTERNATIONAL SCHOOL



# गाजियाबाद नगर निगम


पत्रांक: 4597 /स्वा0/स्व0प्र0प0/22-23

दिनांक:-15/12/2022

## स्वच्छता प्रमाण-पत्र

प्रमाणित किया जाता है कि Scholars International School Plot 363 Pandav Nagar Indl. Area, NH-24, Near Rezapur Railway Flyover, Ghaziabad द्वारा प्रस्तुत पत्र दिनांक 06.12.2022 के क्रम में उक्त स्कूल का निरीक्षण किया गया। निरीक्षण के दौरान स्कूल की सफाई व्यवस्था, शौचालय व मूत्रालय की सफाई व्यवस्था, स्कूल की कक्षाओं का वेंटिलेशन व्यवस्था सामान्य पायी गयी।

अतः उक्त स्कूल को प्रमाण-पत्र वर्ष-2022-23 हेतु इस नियम/शर्त के साथ जारी किया जाता है कि उ0प्र0 प्लास्टिक और अन्य जीव अनाशित कूड़ा-कचरा उपयोग और निस्तारण का विनियमन (संशोधन) अध्यादेश 2018 व ठोस अपशिष्ट प्रबन्धन नियमावली 2016 का अनुपालन सुनिश्चित करेंगे।


  
नगर स्वास्थ्य अधिकारी

गाजियाबाद नगर निगम

Scholars International School

  
Principal



  
MANAGER